



NOTES

If the top of the underfloor heating pipes is to be less than 50mm from the F.F.L., the following applies:

For each of the 4no floor socket locations, a 300 x 300mm square area should be left clear of underfloor heating pipes.

LOCATION PLAN

C: RC CSP2-2027 11/1/06 NOTE UPDATED.
 B: TJH, 05-07-02, CSP2-1606. DIMENSIONS ONLY SHOWN THE 12' WIDE FRAME INCORRECTLY AT 3632mm.
 A: TJH, 25-09-01, CSP2-1549. RE DRAWN ON CAD SHOWING MORE DETAILS.



Tel:Huddersfield(01484)542051 Fax:(01484)539148

**STEEL WALL HINGED ROPE UNIT,
 Floor socket locations.**

scale	date	dr	rev
NTS	25/09/01	TJH	C

dwg no **448-09**