



**NOTES**

Dimensions repeat as detailed opposite ctr line if not shown.

If the top of the underfloor heating pipes is to be less than 50mm from the F.F.L., the following applies:

For each of the 11no floor socket locations, a 300 x 300mm square area should be left clear of underfloor heating pipes.

A: RC CSP2-2027 11/1/06 NOTE UPDATED.



Tel:Huddersfield(01484)542051 Fax:(01484)539148

**TIMBER FOLDAWAY CLIMBING FRAME (THREE GATES),  
Floor socket locations.**

scale	date	dr	rev
NTS	11/09/98	TJH	A

dwg no **448-17**