



**NOTES**

If the top of the underfloor heating pipes is to be less than 50mm from the F.F.L., the following applies:

For each of the 10no floor socket locations, a 300 x 300mm square area should be left clear of underfloor heating pipes.

Frames can be folded in the opposite direction.

LOCATION PLAN

A: RC CSP2-2027 11/1/06 NOTE UPDATED.



Tel:Huddersfield(01484)542051 Fax:(01484)539148

**STEEL TWO in ONE CLIMBING FRAMES (AS ONE PAIR),  
Floor socket locations.**

scale	date	dr	rev
NTS	26/09/01	TJH	A

dwg no **448-21**