



FINISHED WALL LINE

175, 225 or 330

1505

1524

1505

FRAME CAN BE FOLDED EITHER SIDE

REPEAT DIMENSIONS THIS SIDE AS SHOWN OPPOSITE

1524

LOCATION PLAN

**NOTES**

If the top of the underfloor heating pipes is to be less than 50mm from the F.F.L., the following applies:

For each of the 7no floor socket locations, a 300 x 300mm square area should be left clear of underfloor heating pipes.

B: RC CSP2-2027 11/1/06 NOTE UPDATED.  
 A: TJH, 25-09-01, CSP2-1549. RE DRAWN ON CAD SHOWING MORE DETAILS.



Tel:Huddersfield(01484)542051 Fax:(01484)539148

**STEEL TWO in ONE CLIMBING FRAME,  
 Floor socket locations.**

scale	date	dr	rev
NTS	25/09/01	TJH	B

dwg no **448-10**