



FRAME TO BE FOLDED THIS SIDE ↗

**NOTES**

If the top of the underfloor heating pipes are within 50mm of the F.F.L., the following applies:

For the floor socket locations, 1no 450 x 300mm area & 2no 300 x 300mm square areas should be left clear of underfloor heating pipes.

\* The 140mm dimension shown on this drawing is on the basis that no projections / obstructions (radiators, whiteboards, trunking etc) will effect the frames folding back against the wall. If you have any issues please contact us to discuss further.

Frame can be folded in the opposite direction.

LOCATION PLAN

C: RC CSP2-2284 26/7/12. MIN PIVOT DIM SHOWN ONLY. NO OBSTRUCTIONS NOTE ALSO ADDED TO DRAWING.  
 B: IW CSP2-2037 24/2/06 NOTE WORDING CHANGED TO AVOID CONFUSION.  
 A: RC CSP2-2027 11/1/06 NOTE UPDATED.



Tel:Huddersfield(01484)542051 Fax:(01484)539148

TIMBER WALL HINGED SINGLE DOUBLE BEAM,  
 Floor socket locations.

scale	date	dr	rev
1:20	26/09/01	TJH	C

dwg no 448-24